

Test Report

Report No.: YJ2022030131EN

Page 1 of 3

Company Name: Ganzhou Jingde Tesu Wang Wire Co., Ltd

Address: 1st Floor, 2# Plant, Lichang Technology (Ganzhou) Co., Ltd., No. 96 Hubian Avenue, Ganzhou Economic and Technological Development Zone, Ganzhou City, Jiangxi Province

THIS TEST REPORT IS A TRANSLATION OF REPORT NO.: YJ2022030131. IF ANY DISPUTE OR MISUNDERSTANDING HAPPENS, THE CHINESE VERSION PREVAILS.

The following sample(s) and sample information was/were submitted and identified on behalf of the client

Sample Name : Fluorine plastic insulated non-sheathed cables for fixed wiring of rated voltages up to and including 450/750V

Test Requested : GB/T 18380.13-2008

Test Item(s) : Vertical flame spread

Test Information

Sample Received Date : Mar. 25, 2022

Test Period : Mar. 25, 2022 to Mar. 30, 2022

Test Result(s) : Please see attach sheet

Conclusion : Please see attach sheet

Approved by:

WANG junyan, Winson
Authorized Signatory

Date:

Mar. 30, 2022



Zhejiang CTI Foresight Testing Co., Ltd

Room 205-2, 2/F., Building 1, No. 11, Liangzhan Road, Renhe Street, Yuhang District, Hangzhou, Zhejiang, China

Building 13-1, No. 11, Lingang Road, Renhe street, Yuhang District, Hangzhou, Zhejiang, China

Test Report

Report No.: YJ2022030131EN

Page 2 of 3

I. Test method

This test is conducted accordance with GB/T 18380.13-2008 Tests on electric and optical fibre cables under fire conditions –Part 13: Test for vertical flame propagation for a single insulated wire or cable –Procedure for determination of flaming droplets/particles.

II. Sample Details

Sample Description	Cable		
Overall diameter	3.8 mm	Color	Yellow
Marking	BFR-200 450/750V 4.0mm ² CQC1129 赣州敬德特塑王电线有限公司		

III. Traceability record

Conditioning

Temperature	23.0 °C	Relative Humidity	50 % R.H.
Start Time	2022.03.25	End time	2022.03.29

IV. Test Result

Test Items	Specimen	Comment
The filter paper has ignited or not	No	Pass
Time from ignition of the paper to cessation of the burning(s)	--	

- Note: 1. The insulated conductor or cable shall pass the test if the filter paper has not ignited during the test duration.
2. If a failure is recorded two more tests shall be carried out. If both tests result in passes, the insulated conductor or cable shall be deemed to have passed the test.


The test report shall only be used for client scientific research, teaching, internal quality control, product research and development, etc... and just for client internal reference.



Test Report

Report No.: YJ2022030131EN

Page 3 of 3

Photo Appendix

*** End of Report ***

Statement

1. This report is considered invalid without approved signature, special seal and the seal on the perforation;
2. The sample(s) and sample information was/were provided by the client who should be responsible for the authenticity which CTI-FST hasn't verified;
3. The result(s) shown in this report refer(s) only to the sample(s) tested;
4. Without written approval of CTI-FST, this report can't be reproduced except in full.

